

INDUSTRIAL COMPONENT DATA

PTU 6-T 3209535 PHOENIX CONTACT Test disconnect terminal block

Brand: PHOENIX CONTACT | Manufacturer Part Number: PTU 6-T



Manufacturer	PHOENIX CONTACT
MPN / Reference	PTU 6-T
Catalog number	3209535
Category	(Knife) disconnect terminal block
Minimum order	50 Pcs
Document ID	EO-01991293F4
Generated	2026-08-02

Product Overview

Test disconnect terminal block

Borne interrupts. for circ. size, connection type: Push-in connection, Screw connection, cross-section: 0.5 mm² - 10 mm², AWG: 20 - 10, width: 8.2 mm, colour: grey, mounting: NS 35/7.5, NS 35/15

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	PHOENIX CONTACT > Modular TBs
--------------	-------------------------------

Additional Product Information

Key Commercial Data

Orderkey 3209535

Packing unit 50 pc

Minimum order quantity 50 pc

Catalog page Page 109 (C-1-2017)

GTIN 4055626046617

Weight per Piece (excluding packing) 23.260 g

Custom tariff number 85369010

Country of origin CN (China)

General

Number of levels 1

Number of connections 2

Nominal cross section 6 mm²

Color gray
Insulating material PA
Flammability rating according to UL 94 V0
Rated surge voltage 8 kV
Degree of pollution 3
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 1.31 W
Connection method Push-in connection
Connection in acc. with standard IEC 60947-7-1
Maximum load current 41 A (with 10 mm² conductor cross section)
Nominal current I_N 41 A
Nominal voltage U_N 500 V
Connection method Screw connection
Connection in acc. with standard IEC 60947-7-1
Maximum load current 41 A (with 10 mm² conductor cross section)
Nominal current I_N 41 A
Nominal voltage U_N 500 V
Open side panel Yes
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Result of surge voltage test Test passed
Surge voltage test setpoint 7.3 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 1.89 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending test Test passed
Bending test rotation speed 10 rpm
Bending test turns 135
Bending test...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / PTU 6-T with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.