

INDUSTRIAL COMPONENT DATA

PTWE 6-2/F19 3069445 PHOENIX CONTACT Test terminal strip

Brand: PHOENIX CONTACT | Manufacturer Part Number: PTWE 6-2/F19



Manufacturer	PHOENIX CONTACT
MPN / Reference	PTWE 6-2/F19
Catalog number	3069445
Category	Accessories/spare parts for terminals
Minimum order	1 Pcs
Document ID	EO-06A40F9210
Generated	2026-08-02

Product Overview

Test terminal strip

Test pin strip, with VDE type F19 coding, nominal voltage: 400 V, number of connections: 38, number of poles: 19, connection type: Push-in connection, 1st floor, Dimensioning section: 6 mm², section: 0.5 mm² - 10 mm², mounting class: Wall mounting, color: gray

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path PHOENIX CONTACT > Enclosures connectivity

Additional Product Information

Key Commercial Data

Orderkey 3069445

Packing unit 1 pc

Note Made to Order (non-returnable)

Catalog page Page 608 (C-1-2017)

GTIN 4046356943550

Weight per Piece (excluding packing) 549.900 g

Custom tariff number 85369010

Country of origin PL (Poland)

General

Note A detailed circuit diagram can be found under Miscellaneous Downloads

Number of positions 19

Number of levels 1

Number of connections 38
Potentials 19
Nominal cross section 6 mm²
Color gray
Insulating material PA
Flammability rating according to UL 94 V0
Rated surge voltage 4 kV
Test surge voltage 5 kV
Overvoltage category III
Insulating material group I
Maximum power dissipation for nominal condition 1.31 W
Maximum load current 30 A (with 6 mm² conductor cross section)
Current I_{th} 24 A
Nominal voltage UN 400 V AC/DC
Open side panel No
Terminal block mounting 0.8 Nm ... 1 Nm
Insertion/withdrawal cycles mechanical 100
Shock protection test specification DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection guaranteed
Finger protection guaranteed
Note regarding shock protection When test disconnect plug is plugged in.
Result of surge voltage test Test passed
Surge voltage test setpoint 4.8 kV
Result of power-frequency withstand voltage test Test passed
Power frequency withstand voltage setpoint 1.89 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection) Test passed
Result of bending test Test passed
Bending test rotation speed 10 rpm
Bending test turns 135
Bending test co...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / PTWE 6-2/F19 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.