

INDUSTRIAL COMPONENT DATA

UCT1-TM 6 0829483 PHOENIX CONTACT Marker for terminal blocks

Brand: PHOENIX CONTACT | Manufacturer Part Number: UCT1-TM 6



Manufacturer	PHOENIX CONTACT
MPN / Reference	UCT1-TM 6
Catalog number	0829483
Category	Labelling for terminal block
Minimum order	10 Pcs
Document ID	EO-449D21442A
Generated	2026-08-01

Product Overview

Marker for terminal blocks

UniCard materials for thermal transfer printer, for labeling Weidmüller terminals, Conta Clip and Klemsan, 60 units, labelable with THERMOMARK CARD and BLUEMARK LED, color: white

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **PHOENIX CONTACT > MS Material**

Additional Product Information

Key Commercial Data

Orderkey 0829483

Packing unit 10 pc

Minimum order quantity 10 pc

Catalog page Page 170 (C-3-2017)

GTIN 4046356571098

Weight per Piece (excluding packing) 14.390 g

Custom tariff number 39269097

Country of origin PL (Poland)

Dimensions

Length (b) 10 mm

Width (a) 5.55 mm

Height (c) 3.48 mm

Ambient conditions

Ambient temperature (operation) -40 °C ... 120 °C

General

Note Can be labeled via thermal transfer

Color white

Type high

Components free from silicone and halogen

Flammability rating according to UL 94 V0

Material PC

PC

RoHS compliant Yes

Wipe resistance DIN EN 61010-1 (VDE 0411-1)

Number of individual labels 60

Number of individual labels per row 10

Printability Thermal transfer

Inkjet printing

Device 5146464 THERMOMARK CARD

5146480 THERMOMARK CARD-UCT-MAG1

5147888 BLUEMARK LED

5147999 BLUEMARK CLED

Ink ribbon 0801371 THERMOMARK-RIBBON 110-TC

5147421 BLUEMARK FLUID-CARTRIDGE

5146662 BLUEMARK CLED-FLUID-CARTR.

Test for substances that would hinder coating with paint or varnish VW PV 3.10.7:2005-02

Result Test passed

Test specification weathering-resistance Following ISO 4892-2:2013-03

Test duration 96 h

Wipe resistance test result Test passed

Salt spray test specification DIN EN 60068-2-11:2000-02

Test duration 96 min.

Salt spray testing result Test passed

Wipe resistance of test specification inscriptions DIN EN 61010-1 (VDE 0411-1):2011-07

Result Test passed

Marking mounting type snap into tall marker groove

Result Test passed

Oxygen index (DIN EN ISO....

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send PHOENIX CONTACT / UCT1-TM 6 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.