

INDUSTRIAL COMPONENT DATA

590.YA406B SCAME SWITCH DISCONNECTOR 40A 6P B

Brand: SCAME | Manufacturer Part Number: 590.YA406B



Manufacturer	SCAME
MPN / Reference	590.YA406B
Catalog number	10000
Category	Switch disconnecter
Minimum order	1 Pcs
Document ID	EO-0D295441AC
Generated	2026-08-02

Product Overview

SWITCH DISCONNECTOR 40A 6P B
INT. BODY MANEUVER 40A 6P B
40A 6P Y3 BOX (B)

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	SCAME > Switches - SCAME
--------------	--------------------------

Additional Product Information

Commercial SeriesCOMMAND SeriesSynthetical descriptionSWITCH DISCONNECTORConstruction typeOpen typeMounting versionBMaterialTHERMOPLASTICInstallation temperature-25°C/+60°CTypeBOX (B)Rated current40APoles6PSwitch sizeY3Rated voltage690VRated insulation voltage (Ui)690VACRated impulse voltage (Uimp)8kVThermal current (Ithe)40ACurrent (Ie) in AC21A (415V)40ACurrent (Ie) in AC21A (500V)40ACurrent (Ie) in AC21A (690V)40ACurrent (Ie) in AC22A (415V)40ACurrent (Ie) in AC22A (500V)40ACurrent (Ie) in AC22A (690V)40ACurrent (Ie) in AC23A (415V)40ACurrent (Ie) in AC23A (500V)40ACurrent (Ie) in AC23A (690V)25APower AC23A (415V)18.5kWShort-time current1,1kA Icw(1s)Conditional short circuit cur.50kAeffAssociate fuse - type gG40ATerminals - Flexible wires2.5-16mm²Terminals - Rigid wires2.5-16mm²Catalogue notesEquipped with direct handleBOX (B) = Base mountingDIN rail / screw fixing

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send SCAME / 590.YA406B with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.