

INDUSTRIAL COMPONENT DATA

590.YA1004B SCAME SWITCHING UNIT BASE MOUNT.100A 4P BOX

Brand: SCAME | Manufacturer Part Number: 590.YA1004B



Manufacturer	SCAME
MPN / Reference	590.YA1004B
Catalog number	10000
Category	Switch disconnecter
Minimum order	6 Pcs
Document ID	EO-F7F4C53016
Generated	2026-08-02

Product Overview

SWITCHING UNIT BASE MOUNT.100A 4P BOX
BODY INT. MANEUVER 100A 4P B
100A 4P Y4 BOX (B)

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	SCAME > Switches - SCAME
--------------	--------------------------

Additional Product Information

Commercial SeriesCOMMAND SeriesSynthetical descriptionSWITCH DISCONNECTORConstruction typeOpen typeMounting versionBMaterialTHERMOPLASTICInstallation temperature-25°C/+60°CTypeBOX (B)Rated current100APoles4PSwitch sizeY4Rated voltage690VRated insulation voltage (Ui)690VACRated impulse voltage (Uimp)8kVThermal current (Ithe)125ACurrent (Ie) in AC21A (415V)125ACurrent (Ie) in AC21A (500V)125ACurrent (Ie) in AC21A (690V)125ACurrent (Ie) in AC22A (415V)100ACurrent (Ie) in AC22A (500V)100ACurrent (Ie) in AC22A (690V)100ACurrent (Ie) in AC23A (415V)100ACurrent (Ie) in AC23A (500V)63ACurrent (Ie) in AC23A (690V)63APower AC23A (415V)46kWShort-time current1,5kA l_{cw}(1s)Conditional short circuit cur.30kA_{eff}Associate fuse - type gG100ATerminals - Flexible wires10-50mm²Terminals - Rigid wires10-50mm²Catalogue notesBOX (B) = Base mountingDIN rail fixing

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send SCAME / 590.YA1004B with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.