

INDUSTRIAL COMPONENT DATA

590.YA162B SCAME SWITCHING UNIT BASE MOUNT.16A 2P

Brand: SCAME | Manufacturer Part Number: 590.YA162B



Manufacturer	SCAME
MPN / Reference	590.YA162B
Catalog number	10000
Category	Switch disconnecter
Minimum order	6 Pcs
Document ID	EO-B62579A0FB
Generated	2026-08-01

Product Overview

SWITCHING UNIT BASE MOUNT.16A 2P
INT. BODY MANEUVER 16A 2P B
16A 2P Y1 BOX (B)

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	SCAME > Switches - SCAME
--------------	--------------------------

Additional Product Information

Commercial SeriesCOMMAND SeriesSynthetical descriptionSWITCH DISCONNECTORConstruction typeOpen
typeMounting versionBMaterialTHERMOPLASTICInstallation temperature-25°C/+60°CTypeBOX (B)Rated
current16APoles2PSwitch sizeY1Rated voltage690VRated insulation voltage (Ui)690VACRated impulse voltage
(Uimp)4kVThermal current (Ithe)20ACurrent (Ie) in AC21A (415V)20ACurrent (Ie) in AC21A (500V)20ACurrent (Ie) in
AC21A (690V)20ACurrent (Ie) in AC22A (415V)16ACurrent (Ie) in AC22A (500V)16ACurrent (Ie) in AC22A
(690V)16ACurrent (Ie) in AC23A (415V)16ACurrent (Ie) in AC23A (500V)16ACurrent (Ie) in AC23A (690V)16ACurrent (Ie)
in AC3 (415V)18APower AC23A (415V)7.5kWShort-time current400A Icw(1s)Conditional short circuit cur.10kAeffAssociate
fuse - type gG16ATerminals - Flexible wires1.5-10mm²Terminals - Rigid wires1.5-16mm²Catalogue notesBOX (B) = Base
mountingDIN rail fixing

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send SCAME / 590.YA162B with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.