

INDUSTRIAL COMPONENT DATA

3RU1136-4HB1 SIEMENS Overload relay 40...50 A For motor protection Size S2, Class 10 Stand-alone installatio..

Brand: SIEMENS | Manufacturer Part Number: 3RU1136-4HB1



Manufacturer	SIEMENS
MPN / Reference	3RU1136-4HB1
Catalog number	11364
Category	Thermal overload relay
Minimum order	1 Pcs
Document ID	EO-26EC12A979
Generated	2026-08-03

Product Overview

Overload relay 40...50 A For motor protection Size S2, Class 10 Stand-alone installation Main circuit: Screw terminal
Auxiliary circuit: Screw terminal Manual-Automatic-Reset !!! Phased-out product !!! Successor is SIRIUS 3RU2 Preferred
successor type is >>3RU2136-4HB1

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path **SIEMENS > CONTROL AND CONTACTORS > Thermal relays**

Additional Product Information

ETIM: EC000106 - Thermal overload relay
Value Unit
Reset function push-button (EF011942) -
Reset function automatic (EF011941) -
Reset function input (EF011940) -
Adjustable current range (EF008211) ['40', '50'] A
Max. rated operation voltage Ue (EF007357) 690 V
Mounting method (EF000003) Separate positioning
Type of electrical connection of main circuit (EF006819) Screw connection
Number of auxiliary contacts as normally closed contact (EF001377) 1
Number of auxiliary contacts as normally open contact (EF001376) 1
Number of auxiliary contacts as change-over contact (EF003531) 0
Release class (EF006668) CLASS 10

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send SIEMENS / 3RU1136-4HB1 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.