

**INDUSTRIAL COMPONENT DATA**

# 3TH2262-1BB4 SIEMENS Contactor relay, 62E, EN 50011, 6 NO + 2 NC flat connector terminal Width 45 mm 24 V DC..

Brand: SIEMENS | Manufacturer Part Number: 3TH2262-1BB4

|                                                                                   |                 |                 |
|-----------------------------------------------------------------------------------|-----------------|-----------------|
|  | Manufacturer    | SIEMENS         |
|                                                                                   | MPN / Reference | 3TH2262-1BB4    |
|                                                                                   | Catalog number  | 22621           |
|                                                                                   | Category        | Contactor relay |
|                                                                                   | Minimum order   | 1 Pcs           |
|                                                                                   | Document ID     | EO-BA9C864B4C   |
|                                                                                   | Generated       | 2026-08-05      |

## Product Overview

Contactor relay, 62E, EN 50011, 6 NO + 2 NC flat connector terminal Width 45 mm 24 V DC DC operation !!! Phased-out product !!! Successor is SIRIUS 3RH21

**STRUCTURED PRODUCT DATA**

## Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

## Classification & Catalog Path

|              |                                                     |
|--------------|-----------------------------------------------------|
| Catalog path | SIEMENS > CONTROL AND CONTACTORS > Contactor relays |
|--------------|-----------------------------------------------------|

## Additional Product Information

ETIM: EC000196 - Contactor relay  
Value Unit  
With LED indication (EF005950) -  
Interface (EF000594) -  
Manual operation possible (EF005881) -  
Mounting method (EF000003) -  
Rated control supply voltage  $U_s$  at DC (EF003980) ['-', '24'] V  
Voltage type for actuating (EF008242) DC  
Rated operation current  $I_e$ , 400 V (EF001378) 3 A  
Connection type auxiliary circuit (EF006820) Other  
Number of auxiliary contacts as normally closed contact (EF001377) 2  
Number of auxiliary contacts as normally open contact (EF001376) 6  
Number of auxiliary contacts as normally closed contact, delayed switching (EF007281) 0  
Number of auxiliary contacts as normally open contact, leading (EF007282) 0

Number of auxiliary contacts as change-over contact (EF003531) 0  
Rated control supply voltage  $U_s$  at AC 50HZ (EF003978) - V  
Rated control supply voltage  $U_s$  at AC 60HZ (EF003979) - V  
Contactor relay, 62E, EN 50011, 6 NO + 2 NC flat connector terminal Width 45 mm 24 V DC DC operation !!! Phased-out product !!! Successor is SIRIUS 3RH21  
Product designation Auxiliary contactor  
Product type designation 3TH2  
Size of contactor 0  
protection class IP on the front IP20  
Reference code acc. to DIN EN 81346-2 K  
Ambient temperature  
? during operation -25 ... +55 °C  
Type of voltage of the control supply voltage DC  
Control supply voltage at DC  
? rated value 24 V  
Number of NC contacts for auxiliary contacts 2  
? delayed switching 0  
? lagging switching 0  
? make-before-break switching 0  
Number of NO contacts for auxiliary contacts 6  
? d...

## REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send SIEMENS / 3TH2262-1BB4 with the required quantity to [info@electricaonline.com](mailto:info@electricaonline.com) or use [electricaonline.com/request-quote](https://electricaonline.com/request-quote).

### GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.