

INDUSTRIAL COMPONENT DATA

210219 7TAI029020R0007 THOMAS AND BETTS RING TERM CU 14-10 AWG 8 STUD

Brand: THOMAS AND BETTS | Manufacturer Part Number: 210219



Manufacturer	THOMAS AND BETTS
MPN / Reference	210219
Catalog number	7TAI029020R0007
Category	Solderless copper terminals for copper conductors
Minimum order	1000 Pcs
Document ID	EO-21C9DB07CB
Generated	2026-08-02

Product Overview

RING TERM CU 14-10 AWG #8 STUD
DRAGON T. TERMINAL RECTAN. 10,5MM2 M4

STRUCTURED PRODUCT DATA

Technical Specifications

No structured technical attributes are currently available. Submit an RFQ for technical review.

Classification & Catalog Path

Catalog path	THOMAS AND BETTS > Terminals
--------------	------------------------------

Additional Product Information

Extended Product Type:210219

Product ID:7TAI029020R0007

EAN:5414363111764

Catalog Description:RING TERM CU 14-10 AWG NO8 STUD

Long Description:Insulation Piercing Magnet Wire Ring Terminal, Length 1.22 Inches, Width .41 Inches, Length of Teeth .56 Inches, Width of Teeth .38 Inches, Stud Size 8, Wire Range #14 AWG - #10 AWG 4,110 Circular Mil Area - 20,760 Circular Mil Area, Copper Alloy, Tin Plated

Ordering

EAN:5414363111764

UPC:786210839653

Country of Origin:United States (US)

Selling Unit of Measure:each

Container Information

Package Level 1 Units:250 piece

Package Level 1 Width:4.5 in

114 mm

Package Level 1 Height:3 in

76 mm

Package Level 1 Depth / Length:5 in

127 mm

Package Level 2 Units:1000 piece

Package Level 2 Width:9.625 in

244 mm

Package Level 2 Height:3.437 in

87 mm

Package Level 2 Depth / Length:10.75 in

273 mm

Additional Information

Application:For aluminum to copper, aluminum to aluminum or copper to copper magnet wire connections.

Brand / Label:Sta-Kon

Effective Date:19720711

Material:Copper

Product Name:STA-KON AND CATAMOUNT TERMINAL

Product Type:Ring Terminal

Special Functions:Designed to penetrate magnet wire insulation during application, eliminating the need for stripping, brazing, welding or other methods of joining magnet wire.

Standards:UL E9809

Sub Brand / Label:Dragon Tooth

Certificates and Declarations

Data Sheet, Technical Information:210219

Classifications

ETIM 6:EC001052 - Solderless copper terminals for copper conductors

ETIM 7:EC001052 - Solder...

REQUEST PRICE, AVAILABILITY & TECHNICAL REVIEW

Send THOMAS AND BETTS / 210219 with the required quantity to info@electricaonline.com or use electricaonline.com/request-quote.

GLOBAL OFFICES

Germany: Lise-Meitner-Straße 13, 89081 Ulm | USA: 16225 Park Ten Pl #500, Houston, TX 77084 | UAE: HDS Business Centre Tower, Cluster M, 33rd Floor, JLT, Dubai

Catalog-generated document. Product names, marks and specifications belong to their respective owners. Verify safety-critical, compatibility and certification requirements against the manufacturer documentation before purchase or installation.